

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory

No students were present during the time of inspection.

Inspection was conducted during COVID-19 Pandemic.

Email Address(es): raymunoz@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Replace inoperable light bulbs in rooms 369, 370, 209, 216, 237, 238, 247, 256, 161, and 143.

Replace water stained ceiling tiles located in rooms 370, 237, 238, 256, and 170.

Replace missing ceiling tile located in room 370.

Replace biological growth ceiling tiles located in rooms 370, 261, and 164.

Replace cracked electrical outlet located in room 352.

Repair peeled away base board located in room 209.

Replace cracked water fountain handles located across from room 366.

Replace broken light fixture cover located in rooms 161 and 164.

Provide electrical outlet cover in room 143.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

Replace cracked water fountain handles located across from room 366.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Abigail DeFabio (027431)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Miami Sunset Senior H.S.
Date: 7/16/2020

Inspector Signature:

Handwritten signature of Abigail DeFabio.

Client Signature:

emailed to client