

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-08181  
Name of Facility: Miami Sunset Senior H.S.  
Address: 13125 SW 72 Street  
City, Zip: Miami 33183

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

Type: Public Schools  
Owner: M-DCSB Food and Nutrition  
Person In Charge: Miami Sunset Senior H.S. Phone: 3053854255  
PIC Email:

**Inspection Information**

Purpose: Routine  
Inspection Date: 5/16/2023

Begin Time: 10:50 AM  
End Time: 12:40 PM

**Additional Information**

FEMALES ..... 457  
MALES ..... 645  
CENSUS ..... 1102

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION	<b>IN</b> 11. Group Toilet Rooms	<b>IN</b> 21. Pest Control
<b>IN</b> 1. School Site	<b>IN</b> 12. Toilet Facilities	SAFETY
<b>IN</b> 2. Playground, Equip & Athletic Fields*	<b>IN</b> 13. Handwashing Facilities	<b>IN</b> 22. First Aid Kit
<b>IN</b> 3. Athletic & Playground Equipment	<b>OUT</b> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<b>IN</b> 15. Shower Facilities	<b>NA</b> 23. Sanitizers
<b>NA</b> 4. Construction	<b>IN</b> 16. Showers Water Temperatures	<b>NA</b> 24. Changing Station & Mats
<b>OUT</b> 5. Maintenance & Repair	WATER SUPPLY	<b>NA</b> 25. Hand Sink
<b>IN</b> 6. Lighting Standards	<b>IN</b> 17. Approved Source	<b>NA</b> 26. Garbage Can
<b>IN</b> 7. Heating, Ventilation, A/C Standards	<b>IN</b> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<b>IN</b> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<b>NA</b> 27. Animal Maintenance/Aggressive
<b>IN</b> 9. Mechanical Ventilation	<b>IN</b> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<b>IN</b> 20. Solid Waste	<b>NA</b> 28. Maintenance/Complaint
<b>IN</b> 10. Provided/Accessible/Separation	PEST CONTROL	<b>NA</b> 29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: \* = 2. Playground, Equipment & Athletic Fields

**General Comments**

Satisfactory.

Email Address(es): raymunoz@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

**Violation #5. Maintenance & Repair**

At the time of inspection, the lightbulbs were out at classrooms 151,170,142,143,251,204,288,292,280, and 267. Provide lightbulbs.

At the time of this inspection, ceiling tiles with water marks were observed at classrooms 273,297,224,221,275,185,178,251,257,293,188, and 187. Replace ceiling tiles.

At the time of inspection, the ceiling tiles were observed missing at classrooms 280,257, and 251. Provide ceiling tiles.

At the time of the inspection, the light cover was observed missing at classroom 260. provide light cover.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

**Violation #14. Soap Dispensers**

At the time of inspection, soap dispensers were observed missing at bathroom 156. Provide soap dispensers.

CODE REFERENCE: 14. Soap Dispensers. 468.3.5.7.2 FBC. Soap dispensers for liquid, foam or powdered soap shall be provided at all handwashing basins. 5(10)(f) SREF. Dispensers for liquid, foam, or powdered soap shall be maintained in a safe & secure condition at all times.

Inspection Conducted By: Bader Alsuliman (9132510)

Inspector Contact Number: Work: (305) 623-3500 ex.

Print Client Name: Raydelin Munoz

Date: 5/16/2023

Inspector Signature:

Client Signature: